



ROAD DEPARTMENT

**ADDENDUM NO. 2**  
**SIX CORNERS IRRIGATION PIPING IMPROVEMENT**

The Bidding Documents for the Six Corners Irrigation Piping Improvement project are amended as follows:

**PROJECT PLANS**

**Sheet C1.2** – Revise Irrigation Construction Note 1 to state the following:

Install 18" C900 PVC DR 25 or DR 32.5 PVC pipe.

**Sheet C1.3** – Revise Central Oregon Irrigation District Piping Specifications General Note 1 to state the following:

All irrigation piping shall be constructed of AWWA C900 PVC DR 25 or DR 32.5.

\_\_\_\_\_  
Cody Smith, PE  
County Engineer

12-5-18

\_\_\_\_\_  
Date

\_\_\_\_\_  
I acknowledge receipt of Addendum Number 2.

\_\_\_\_\_  
SIGNATURE OF BIDDER

\_\_\_\_\_  
Date

**THIS ADDENDUM, COMPLETE WITH ATTACHMENTS, SHALL BE SUBMITTED WITH BID PROPOSAL.**